



Hutto Fire Rescue

Williamson County Emergency Services District #3
 P.O. Box 175, Hutto, TX 78634
 Phone (512) 759-2616 FAX (512) 846-1946



PLANS REVIEW

Fire Inspections Division must review the following plans:

- Site/Civil
- Hood & Booth system
- Building remodel
- Any fire extinguishing systems
- Shell only- Shell Finish Out
- New building plan
- Fire sprinkler system
- Fire alarm system

INSPECTIONS

Fire Inspections Division must inspect the following:

Sprinkler Systems

- Visual on all sprinkler heads & piping
- Fire pump acceptance test
- Fire final
- Hydrostatic test on all piping including underground
- Thrust blocks on private fire lines, hydrants, and risers
- Knox caps for FDC

*** Before system is accepted a copy of the sprinkler system to include any changes made must be burned to a disk in PDF and turned into the Fire Inspector.*

Fire Alarm Systems

- Fire alarm acceptance test
- Flow test
- Anything the fire alarm is responsible for, and/or connected to, such as, but not limited to: elevators, kitchen hoods, fire pumps, etc
- Elevator phase I & II
- Fire Final

*** Before system is accepted a copy of the fire alarm system to include any changes made must be burned to a disk in PDF and turned into the Fire Inspector.*

Hood & Booth Systems

- Acceptance test on any fire suppression hood system including, but not limited to: kitchens, paint booths, etc.

Fire Final

- Must have fire final prior to application for Certification of Occupancy.

A Fire final includes, but not limited to the following:

- Means of egress-exit signs, emergency lighting
- Fire lane stripping
- All fire caulking completed
- Master, elevator, and any keys for the Knox Box
- All applicable fire codes and local ordinances

Automatic Gates

- Minimum width 25' (single gate)
- Minimum width 15' (double gate – travel one direction)
- Manual override for auto gates
- Knox key Switch
- Must have inspection

All supplement inspection and acceptance test must be completed and passed prior to the fire final.

To order KNOX boxes, FDC caps, key switches and locks contact by Hutto Fire Rescue.

To schedule an inspection, or acceptance test contact Hutto Fire Rescue @ (512) 759-2616